

JIANGXI GILARDINO BUILDING MATERIALS TECHNOLOGY CO.,LTD
ZHONGXIN ROAD, YUJIANG INDUSTRY PARK, YUJIANG COUNTY, YINGTAN CITY, JIANGXI PROVINCE

The following sample(s) was/were submitted and identified on behalf of the client as:

Sample Description : SPC FLOORING
SGS Ref No. : XMIN190601490CCM
Sample Receiving Date : Jun. 27, 2019
Test Performing Date : Jun. 27, 2019 to Jul. 8, 2019
Test Performed : Selected test(s) as requested by applicant
Test Result(s) : For further details, please refer to the following page(s)

Signed for and on behalf of
Xiamen Branch, SGS-CSTC Co., Ltd.



Beck Hong
Approved Signatory



SGS-CSTC Inspection & Testing Services Co., Ltd.
Xiamen Branch Testing Center Handlines

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.31 Xianghong Road, Xiang'an Torch Industrial Zone, Xiamen, Fujian Province, China 361101 t (86-592) 5766537 f (86-592) 5766460 www.sgsgroup.com.cn
中国·福建·厦门·火炬(翔安)产业区翔虹路31号 邮编: 361101 t (86-592) 5766537 f (86-592) 5766460 e sgs.china@sgs.com

Sample Information:

Flooring, See the photograph(s).

Lab environment condition: 23±2°C, 50±5%RH

Preconditioning: 23±2°C, 50±5%RH for a minimum of 24h

Test result(s):


No.	Test item(s)	Test method(s)	Test condition	Test result(s)
1	Dimensional stability (see note 2)	ASTM F2199-18	Specimen: 610mm×184mm×4mm, 3pcs Condition: 23±2°C, 50±5%RH, 24h	Average: X Direction: -0.02% Y Direction: 0.03%
2	Curling (see note 3)		→82±2°C, 360min→ 23±2°C, 50±5%RH, 24h	Average: Curling _{value} : 0.16mm Curling _{max} : 0.26mm

Note: 1. All test specimens were cut from the samples, see the photograph(s).

2. Dimensional stability, % = (The average final length – The average initial length)/The average initial length ×100.

3. Curling, mm = Dimension after exposure to heat - Dimension before exposure to heat.

Sample photo(s):



Original sample(s)

The testing report/certificate only refers to the sample(s) tested.

End of Report



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC Inspection & Testing Services Co., Ltd.
Xiamen Branch Testing Center Handlines

No.31 Xianghong Road, Xiang'an Torch Industrial Zone, Xiamen, Fujian Province, China 361101 t (86-592) 5766537 f (86-592) 5766460 www.sgs.com.cn
中国·福建·厦门·火炬(翔安)产业区翔虹路31号 邮编: 361101 t (86-592) 5766537 f (86-592) 5766460 e sgs.china@sgs.com